

3-29-00

12.3.42

PERMITTEE NAME/ADDRESS:

Name: Lafarge Corporation
 Address: 5400 W. Marginal Way
 Seattle, WA 98106

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

WA-0002232

PERMIT NUMBER

001

DISCHARGE NUMBER

FORM APPROVED

OMB No. 2040-0004

Discharge Location

Lat 47° 33' 30" N

Long 122° 28' 58" W

NO DISCHARGE

Facility: Same As Above

Location: Same As Above

MONITORING PERIOD

FROM	02/01/2000	TO	02/29/2000
------	------------	----	------------

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53)	Quantity or (54-61)	Loading	(4 Card Only) (38-45)	Quality or (46-53)	Concentration (54-61)	Unit	NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)	
		Average	Maximum	Unit	Minimum	Average	Maximum					
TSS	SAMPLE MEASUREMENT	—	—	—	—	—	—	mg/L	0	1/30	Grab	
	PERMIT REQUIREMENT	—	—	—	—	—	50			1/30	GRAB	
pH	SAMPLE MEASUREMENT	—	—	—	—	—	—	STD	0	1/30	Grab	
	PERMIT REQUIREMENT	—	—	—	6.0	—	9.0			1/30	GRAB	
OIL & GREASE	SAMPLE MEASUREMENT	—	—	—	—	—	—	mg/L	0	1/30	Grab	
	PERMIT REQUIREMENT	—	—	—	—	—	10			1/30	GRAB	
TURBIDITY OF EFFLUENT	SAMPLE MEASUREMENT	—	—	—	—	—	—	NTU	0	1/30	Grab	
	PERMIT REQUIREMENT	—	—	—	—	—	Background + 10			1/30	GRAB	
TURBIDITY OF BACKGROUND	SAMPLE MEASUREMENT	—	—	—	—	—	—	NTU	NA	1/30	Grab	
	PERMIT REQUIREMENT	—	—	—	—	—	REPORT			1/30	GRAB	
DIFFERENCE OVER BACKGROUND TURBIDITY	SAMPLE MEASUREMENT	—	—	—	—	—	—	mg/L	0	1/30	Grab	
	PERMIT REQUIREMENT	—	—	—	—	—	REPORT			1/30	GRAB	
TOTAL RECOVERABLE COPPER	SAMPLE MEASUREMENT	—	—	—	—	—	—	mg/L	0	4/yr	Grab	
	PERMIT REQUIREMENT	—	—	—	—	—	REPORT			4/YR	GRAB	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THIS INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC, 1001 AND 33 USC, 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TELEPHONE		DATE	
Russ Simonson, Environmental Engineer									(206) 937-8025		29 0300	
TYPED OR PRINTED									AREA CODE NUMBER		DAY MO YEAR	

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

* TURBIDITY SHALL NOT EXCEED 10 NTU OVER BACKGROUND WHEN BACKGROUND IS 50 NTU OR LESS, AND SHALL NOT EXCEED BACKGROUND BY MORE THAN 20% WHEN BACKGROUND IS GREATER THAN 50 NTU.



RECEIVED

PAGE 1 OF 2

APR 06 2000

DEPT OF ECOLOGY